

Report Number: XXXX

Report Date: XXXX

Client: Joe Smith  
123 Main St  
Anywhere Ma. 01234

Sample Information: Address of Property Inspected

Sampled by: Clayton Home Inspecti Date Received: XXXX

Date Sampled: XXXX

## Certificate of Analysis


<u>Test Parameter</u>	<u>EPA Limit</u>	<u>Results</u>	<u>Units</u>
Total Coliform (P)	0	0	per100ml
Fecal Coliform/ E.coli (P)	Absent	Absent	per100ml
Arsenic (P)	0.05	<0.002	mg/L
Calcium	Not Spec.	18.7	mg/L
Copper (S)	1.3	<0.02	mg/l.
Iron (S)	0.3	0.06	mg/L
Lead (P)	0.015	<0.001	mg/L
Magnesium	Not Spec.	4.5	mg/l.
Manganese (S)	0.05	0.02	mg/l.
Potassium	Not Spec.	3.8	mg/L
Sodium	See Note	43.1	mg/L
Alkalinity (S)	Not Spec.	92.0	mg/l.
Ammonia-N	Not Spec.	<0.03	mg/L
Chloride (S)	250	1.9	mg/L
Chlorine	Not Spec.	<0.02	mg/l.
Color (S)	15	0	CPU
Conductivity	Not Spec.	230	umhos/cm
Fluoride (S)	4.0	1.9	mg/L
Hardness	Not Spec.	65	mg/l.
Nitrate-N (P)	10	<0.01	mg/L
Nitrite-N (P)	1	<0.05	mg/L
Odor	3	0	TON
pH (S)	6.5-8.5	7.3	SU
Sulphate (S)	250	15.7	mg/l.
Turbidity	Not Spec.	0.35	NTU
Sediment	pos/neg	neg	

### Legends:

(P)-Primary EPA Standard, (S)-Secondary EPA Standard, // -Exceeds EPA Limit,  
TNTC-Too Numerous to Count, \* =Background Bacteria Noted, ' = Exceeds Advisory Limit  
Sodium Advisory Limits, Mass.-20, NH -250.

This water sample as submitted, meets EPA/FHA requirements for the parameters listed above.  
The quality of this water is accepted as POTABLE according to EPA/FHA Standards.

Massachusetts Certification # MA048



Michael P. Carlson, for  
Thorstensen Laboratory Inc.

Report Number:

Report Date:

Date Sampled:

Sampled by: Clayton Home Inspection

VOC scan

PARAMETER	MCL	RESULT	PARAMETER	MCL	RESULT
Benzene	5.0	ND	1,1,2,2-Tetrachloroethane	--	ND
Carbon Tetrachloride	5.0	ND	1,3-Dichloropropane	--	ND
1,1-Dichloroethylene	7.0	ND	Chloromethane	--	ND
1,2-Dichloroethane	5.0	ND	Bromomethane	--	ND
p-Dichlorobenzene	5.0	ND	1,2,3-Trichloropropane	--	ND
Trichloroethylene	5.0	ND	1,1,1,2-Tetrachloroethane	--	ND
1,1,1-Trichloroethane	200.	ND	Chloroethane	--	ND
Vinyl Chloride	2.0	ND	2,2-Dichloropropane	--	ND
Monochlorobenzene	100.	ND	o-Chlorotoluene	--	ND
ortho-Dichlorobenzene	600.	ND	p-Chlorotoluene	--	ND
trans-1,2-Dichloroethylene	100.	ND	Bromobenzene	--	ND
cis-1,2-Dichloroethylene	70.0	ND	1,3-Dichloropropene	--	ND
1,2-Dichloropropane	5.0	ND	1,2,4-Trimethylbenzene	--	ND
Ethylbenzene	700.	ND	1,2,3-Trichlorobenzene	--	ND
Styrene	100.	ND	n-Propylbenzene	--	ND
Tetrachloroethylene	5.0	ND	n-Butylbenzene	--	ND
Toluene	1000.	ND	Naphthalene	--	ND
Xylenes(Total)	10000.	ND	Hexachlorobutadiene	--	ND
Dichloromethane	5.0	ND	1,3,5-Trimethylbenzene	--	ND
1,2,4-Trichlorobenzene	70.0	ND	p-Isopropyltoluene	--	ND
1,1,2-Trichloroethane	5.0	ND	Isopropylbenzene	--	ND
Chloroform	--	ND	t-Butylbenzene	--	ND
Bromodichloromethane	--	ND	sec-Butylbenzene	--	ND
Chlorodibromomethane	--	ND	Fluoro Trichloromethane	--	ND
Bromoform	--	ND	Dichlorodifluoromethane	--	ND
m-Dichlorobenzene	--	ND	Bromochloromethane	--	ND
Dibromomethane	--	ND	*Methyl Tertiary Butyl Ether	--	ND
1,1-Dichloropropene	--	ND			
1,1-Dichloroethane	--	ND			

% Recovery of Internal Standards:

4-Bromofluorobenzene 81

1,2-Dichlorobenzene-d 85

Detection Limit: 0.5 ug/L

ND=None Detected

MCL= Maximum Contamination Level

Results are in ug/L

\*MTBE (Optional)



Michael P. Carlson, for

Thorstensen Laboratory Inc.